

Confirmation

LEED

On 22 March 2016, Eurofins Product Testing A/S received a sample of an adhesive with the product name:

Seal-It 220 Silicon FR

supplied by

Connect Products

The sample was supplied as being representative of the manufactured product, and it has been tested as Multipurpose Construction Adhesive in accordance with the relevant ASTM D2369, ISO 11890-1 and EPA method 24 testing standards (See test report no. 392-2016-00118701_01).

The test results of the tested adhesive indicate that the product qualifies for LEED 2009 specifications on VOC content by complying with:

VOC content specifications in LEED EQ credit "Low-emitting products":

- The requirements of SCAQMD rule 1168 (2005)

8 April 2016



Morten Sielemann
Analytical Chemist